

OAK MEADOWS FIRE HYDRANTS

HYDRANT #	ADDRESS	ADDRESS	MAKE AND MODEL	STATIC #	NOTES	NOTES	CHECKED
# 1	Sth of Sewer Plant		Mueller 00	115#	Very stiff dug out		JMcD
#2	68 Beaver Court		Mueller 00	100#	Valve box full of mud		JMcD
#3	#19 Nth Meadow View		Mueller 76	90#	Dug out		JMcD
#4	Island Sth Meadowview C		MandH 78	85#	Dug out		JMcD
#5	0025 Sopris Ct		MandH 78	80#	Dug out		JMcD
#6	Sunlight Ct		MandH 78	75#	Dug out		JMcD
#7	0225 Sth Oak way		MandH 78	45#	Lot of air Dug out		JMcD
#8	0090 W Sunlight Ct		MandH 78	70#	Dug out		JMcD
#9 #10 #11	NOT INSTALLED YET						
#12	Old Midland		Mueller 03	75#	Dug out		JMcD
#13	Old Midland		Mueller 03	75#	Dug out		JMcD
#14			Mueller 03	110#	Dug out		JMcD
#15			Mueller 03	90#	Dug out		JMcD
#16	Haystack btw Lots 27/28		Mueller 00	95#	Dug out		JMcD
#17	Haystack Lot 32		MandH 78	70#	Dug out		JMcD
#18	Haystack/Old Midland		Mueller 00	70#	Dug out / too low		JMcD
#19	Old Midland Lot 6		Mueller 00	45#	Dug out		JMcD
#20	Old Midland/Mueller		Mueller 03	110#	Dug out		JMcD
#21, #22, #23	PRIVATE						
#24	Sunking past Dumpster		Mueller 78	100#			JMcD
#25	2nd Hyd past dumpsters		Mueller 78	75#	Dug out		JMcD

Notes:

#26 In cul de sac top Sking Mueller 03 60# Dug out JMcD

All hydrants checked by Western Colorado Hydrant and Valve